



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/08/2026

Shift: A

Incharge(s): G Eswara Rao, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-26	OLR ACTED	RESET DONE	09:45:00	09:50:00	
2	OHP	WOBR ON CO-26	REPORTED B/C NOT RUNNING FOUND ZSS PROBE DAMAGE	PROBE REPLACED THAN OK	12:00:00	12:40:00	
3	CHP	CC-52	MPD TRIP (FEEDING CONVEYOR STOP)	RESET DONE	08:10:00	08:15:00	
4	CHP	CC-51	MPD TRIP	RESET DONE	13:00:00	13:05:00	
5	CHP	CC-9	REPORTED STOPPING ON ZSS AND MOTOR NOT RUNNING CHECKED AND FOUND POWER MCCB TRIP	MADE ON THAN OK	13:15:00	13:40:00	