



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/06/2026

Area: OHP

Equipment	Job
tbs-6 on co-7a	LT thruster brake CRMP side replaced and trail run is taken.
tbs-6 on co-7a	LT thruster brake CRMP side replaced and trail run is taken.
tbs-1 on co-23, co-22,23	ppm is done. tbs-1 RBC additional lamp provided for pile focus
tbs-1 on co-23, co-22,23	ppm is done. tbs-1 RBC additional lamp provided for pile focus
TBS spare HT transformer	received from ERS, kept at HVMCC-1
TBS spare HT transformer	received from ERS, kept at HVMCC-1
losp-1 vs level	lighting is improved.
losp-1 vs level	lighting is improved.
om-9,om-10, om-11	mcc control bus and io racks ppm is done
om-9,om-10, om-11	mcc control bus and io racks ppm is done
co-5	wall side lighting is improved in tunnel
co-5	wall side lighting is improved in tunnel
jh o-2 co-5 hoist	CT motor megger values are ok, Checked with EMC, found faulty, spare to be checked. Ldb, pdb ppm is done.
jh o-2 co-5 hoist	CT motor megger values are ok, Checked with EMC, found faulty, spare to be checked. Ldb, pdb ppm is done.
om-15,16,om-24, 1-141lc3,1-141lc4	MCC room housekeeping is done.
om-15,16,om-24, 1-141lc3,1-141lc4	MCC room housekeeping is done.