



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	TRIPPED ON OLR/2TIMES	RESET DONE	07:10:00 09:15:00	07:15:00 09:25:00	
2	OHP	VS 5A	TRIPPED ON OLR	RESET DONE	07:00:00	07:10:00	
3	OHP	WOBR ON CO 6A	LT NOT TAKING PLACE/M3 OLR ACTED	RESET DONE	13:10:00	13:20:00	THRUSTOR BRAKE TO BE CHECKED
4	OHP	CO 25	TRIPPED ON OLR RESET DONE	RESETD ONE	13:45:00	13:55:00	
5	CHP	SCR 8 ON CC112	BC STOPPING FREQUENTLY/ZSS CAGE STUCKUP WITH MATERIAL	CAGE MADE FREE THEN OK	06:35:00	06:50:00	
6	CHP	CC 201	MPD TRIPPED IN OLR	RESET DONE	06:55:00	07:00:00	
7	CHP	SCR 4 ON CC32	BC NOT RUNNING/NOT SELECTD MODE	STACKING MODE SELECTED	08:20:00	08:30:00	
8	CHP	CC 104	ZSS ACTING/DUE TO MATERIAL	PROBE CLEANING DONE	09:00:00	09:10:00	
9	CHP	CC 48	C/S ACTED /CHUTE JAMMING	INFORM TO OPERATION	09:50:00	10:00:00	
10	WT	CT 2	F/REVERSE NOT TAKING PLACE/REVERSE CONTACT NOT MAKING PROPERLY IN ROTARY LIMIT AT M2.	CONTACT CLEANING DONE THEN OK	08:50:00	09:20:00	