



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/10/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-30	CT not taking place	Drive tripped.Reset done	02:50:00	03:05:00	
2	OHP	CO-26	Reported tripped	OLR acted.Reset done	03:55:00	03:45:00	
3	OHP	CO-10A	Reported tripped	OLR acted.Reset done	05:05:00	05:15:00	
4	OHP	BRC on CO-32	PCRD tension acted	Manually made down	04:35:00	04:50:00	To be checked and to be rectfied
5	CHP	S-3 on CC-112	B/C not running	OLR acted.Reset done	22:50:00	23:05:00	
6	CHP	SCR-5 on CC-32	LT not taking place	PCRD tension acted.Released	00:45:00	01:00:00	