वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 04/11/2026

Shift: B

Incharge(s): M Kailash

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | WOBR ON CO-26 | Luffing not working. MPCB tripped | Reset done | 14:30:00 | 14:50:00 | |
| 2 | OHP | WOBR ON CO-26 | Luff up not working. Found UP limit switch stuck up | Released and tested OK | 15:10:00 | 15:25:00 | |
| 3 | OHP | BRC ON CO-28 | LT not working. Found selector switch is in Local mode | Kept in PLC and tested OK | 15:45:00 | 15:55:00 | |
| 4 | OHP | CO-25 | Overload acted | Reset done | 17:40:00 | 17:55:00 | |
| 5 | OHP | VS-1A | Reported Red. Overload acted | Reset done | 21:20:00 | 21:25:00 | |
| 6 | OHP | BRC ON CO-8A | pump is stopping in 5 sec after starting. Found charge pressure P1 not healthy in HMI. But found pump 2 running. | Glass relay is not picking up. Bypassed and checked. suspected festoon cable stretching. Relay is picking for some time and dropping | 18:00:00 | 20:00:00 | To be checked further. |
| 7 | OHP | CO-6A | BRS not getting reset | kept bypass and informed to c.shift | 21:50:00 | 22:10:00 | to be kept in circuit after checking |
| 8 | CHP | LC-19 | Area shop office, NO POWER. Found Incomer-2 tripped on earth fault. | Reset done and made ON | 21:00:00 | 21:15:00 | tripping regularly. to be checked |
| 9 | CHP | SCR-6 ON CC-38 | LT not working. Found Local/Remote selector switch is in Local Mode | Kept in Remote mode and tested OK | 15:10:00 | 15:20:00 | |
| 10 | CHP | CC-215 | Overload acted | Reset done | 15:25:00 | 15:35:00 | |
| 11 | CHP | RECL-1 ON CC-36 | B/C not running. Found ZSS acted. due to material full jamming on belt. Belt is slipping | Material cleaned and then made OK | 20:30:00 | 21:10:00 | No electrical complaint |
| 12 | CHP | CC-14 | ZSS acted. Found cage stuck up with coal. | Made free and tested OK | 17:50:00 | 18:00:00 | |

वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 04/11/2026

Shift: B

Incharge(s): M Kailash

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 13 | IOSA | VF-3 | Tripped on overload | Reset done | 16:25:00 | 16:40:00 | two times |