



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/05/2026

Area: WT

Equipment	Job
CT 1	Hooter replaced
OAF 1 and 2 level	2 nos 35W LED fittings replaced
CO 3 and 4	Motors Fan covers fixing done
CP 2	Panel and Motor side ppm done
CP 2	3 nos Section isolator boxes maintenance done,completed
CP 3	Testing done both directions ,found OK
OP 5	Roof sheets welding done