



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/08/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR 1	OLR acted	Reset	17:20:00	17:30:00	
2	OHP	Rsc0 2a	CD MPCB trip	Made it on	18:00:00	18:10:00	
3	OHP	CO 25	OLR acted	Reset	18:10:00	18:20:00	
4	OHP	WBR on CO 6A LT	Selector switch is in LOCAL mode	Changed to Remote	18:05:00	18:15:00	
5	CHP	SCR 5 on CC 32	PCRD cable Fell down	Winding done	16:20:00	16:40:00	
6	CHP	CC 35	ZSS Probe Damaged	Replaced	17:15:00	17:45:00	
7	CHP	SCR 2 on CC 33	B/W drive trip	Reset	18:30:00	18:45:00	
8	CHP	CC 21 CD	MPCB trip	Reset	17:00:00	17:10:00	