



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 05/09/2026

Area: CHP

| Equipment                            | Job                                                             |
|--------------------------------------|-----------------------------------------------------------------|
| CC 130                               | Motor replaced,alignment done.Trail run pending                 |
| CC 7,15                              | PPM was done                                                    |
| CC 222 gallery                       | 3 nos 70W SV fixtures arranged                                  |
| SCR 7                                | Lighting cable jointed inside the chamber and restored lighting |
| CC 37                                | Burnt motor coupling removed and sent to ERS                    |
| CC 40,107,SCR<br>7,CC216,218,220,222 | PPM was done                                                    |