



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/07/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 29 LUFF	OLR ACTED	RESET	04:10:00	04:25:00	
2	CHP	CC 26A MCCB TRIPPING	MCCB SETTING DISTURBED	READJUSTED	23:00:00	23:30:00	
3	WT	OP6	BREAKER TRIPPING FREQUENTLY	C TYPE ISOLATOR KEPT OFF AT COLL NO 46	23:30:00	00:15:00	