



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/10/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 47	stopping in ZSS,operation told to change the module and probe	checked probe and module all found ok,bypass ZSS for 5 minutes at that time return coming continuously in zss module,told operation our side all ok	01:45:00	02:10:00	not electrical delay told operation i/c s
2	OHP	wobr on co 25	slew not working towards crmp side,limit switch stucked	limit switch released	23:10:00	23:20:00	
3	OHP	CO 29	olr acted	reset	23:40:00	23:50:00	4 times
4	OHP	co 25	olr acted	reset	02:50:00	03:00:00	
5	OHP	wobr on co 25	operator fan not working,mcB tripped	made it on	03:00:00	03:10:00	
6	OHP	co 10 A	olr acted	reset	23:10:00	23:15:00	
7	OHP	CO 14 B	olr acted	reset	01:00:00	01:07:00	
8	OHP	CR 2	lubrication pump tripped	made on	01:10:00	01:30:00	
9	CHP	CC 39 R1	b/c not running,common high fuse blown	fuse replaced	01:50:00	02:00:00	
10	CHP	CC 105 scr10	slew left not working,jamming	informed to operation	03:40:00	03:55:00	
11	CHP	CC 37 SCR3	b/c not working,c/s acted	informed operation for jamming	04:55:00	05:10:00	
12	CHP	cc 31	olr acted	reset	05:12:00 05:50:00	05:18:00 05:55:00	
13	CHP	CC 38	tripped in CURT SP fault	reset	05:25:00	05:30:00	
14	CHP	CC 51	OLR acted	reset	01:20:00	01:25:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/10/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC 51	mpd acted	reset	23:55:00	00:00:00	4 times b/w 2355 to 0145
16	CHP	CC 52	mpd tripped 2 times	reset	23:50:00	23:55:00	