RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 04/11/2026

Area: WT

Equipment	Job
MIS	PLC MADE READY FOR LC-10A
OP-5	TROLLEY LINE CHECKING AND PROBLEM RECTIFICATION DONE
CP-4	REVERSE LIMIT STRIKER ADJUSTED
LC-10A	FEEDER 2 BUSBAR DUCT COVERED WITH TARPAULIN TO A AVOID WATER ENTRY
LC-10A	MAINTENANCE DONE