



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 30/06/2026

Area: WT

Equipment	Job
OT 5	Limit switch LS 4 checked found ok
CP 3	Lighting connection done
OP 3	Trolley line inspection done
OP 2	D2 motor shifted, placed on the bed and testing done
OP 2	D5 motor removed for gear box repair job