वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/10/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 7a	LT not working,olr acted	reset	02:05:00	02:20:00	
2	OHP	co 25	olr acted	reset	05:20:00	05:25:00	
3	OHP	brc on co 32	LT not working,olr acted	reset	05:00:00	05:20:00	
4	OHP	CO 70	mpr acted,mpr problem not getting reset	bypassed	05:45:00	05:55:00	to be changed
5	CHP	CC 131	motor tripped,olr acted	reset	03:30:00	03:35:00	2 times
6	CHP	CC 54	olr acted	rset	02:00:00	03:00:00	3 times
7	CHP	CC 112	S3,bc not running,tripped in CURT SP fault	reset	22:40:00	22:55:00	
8	WT	OP9	communication problem	ethernet cable unplugged ,cleaned and re plugged in modem of OT5 bridge and power recycle	02:30:00	03:15:00	way to tippler blocked due to wagon grouping