RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 11/11/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CC 108	OLR acted	Reset	19:20:00	21:15:00	2 times
2	OHP	CO 25	OLR acted	Reset	21:00:00	21:05:00	
3	OHP	TBS on CO 7a	Drive trip	Reset	15:35:00	15:50:00	
4	OHP	BRC on co 8a	LT M2 trip	Reset	17:30:00	17:56:00	
5	OHP	BRC on Co 33m	Drive trip	Reset	18:50:00	19:00:00	
6	OHP	BRC on CO 31	B/C OLR acted	Reset	19:05:00	19:15:00	
7	CHP	SCR 5 on CC 32 LT	Drive trip	Reset	15:00:00	15:15:00	
8	CHP	SCR 7 On CC 40 B/C	Signal missing	PLC power recycled then ok	15:30:00	17:50:00	2 times
9	CHP	CC 213 Not running	CC 213 to CC 216 programming not there	Programming done	17:00:00	17:30:00	
10	CHP	CC 131	OLR acted	Reset	19:10:00	20:00:00	3 times
11	WT	OP4 D2	OLR acted	Reset	17:00:00	17:05:00	
12	IOSA	OC7b, OC21a, OC14a Red	DC 220v Failure	Supply Given From DNw setup	17:00:00	22:00:00	Restoration Under Progress