



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/06/2026

Area: WT

Equipment	Job
CT-2	OUT HAUL SIDE REV LIMIT CHECKED AND KEPT IN CKT
MIS	55KW SPARE MOTOR TERMINAL BLOCK FIXED
MIS	SPARE MOTOR 55KW COUPLING FIXED AND MADE READY
OT-4	BURNT MOTOR COUPLING REMOVED AND SENT TO ERS