



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/07/2026

Area: CHP

Equipment	Job
JH C6	Hoist panels maintenance was done
CC 21 Carriage drive	Motor overhauling done, fixed the motor and trail run taken
SCR 1	Cabin top one 200W fixture replaced
CC 43/44 tunnel	6 nos 35W LED fixtures provided and improved lighting
CC 32, SCR 4	PPM was done
CC 215	Chute sensor probe adjusted, ZSS module replaced
S 3, SCR 5	Yard machine shifting done
RG 1, CC 132	PPM was done