



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/10/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	17:20:00	17:28:00	2 times
2	CHP	CC 106 SCR8	slew and b/w not working,oil level low	informed mech	18:15:00	18:25:00	
3	CHP	CC 40 SCR7	b/c not working	checked and found all ok	18:50:00	19:00:00	
4	CHP	CC 28 TT	not working,mccb is in off	made it on	20:50:00	21:00:00	
5	CHP	CC 203	olr acted	reset	21:20:00	21:30:00	
6	CHP	CC 54	olr acted	reset	20:05:00	20:10:00	
7	CHP	CC 114	PC acted	reset	15:10:00	15:20:00	
8	IOSA	FLS wob on oc17a	bc not running,zss cage yard interlock problem	stone removed form cage	17:30:00	17:40:00	