



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/06/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	04:45:00	04:55:00	
2	OHP	TBS ON CO 21 LT	SELECTOR SWITCH IN LOCAL	CHANGED TO REMOTE	05:25:00	05:35:00	
3	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:55:00	01:25:00	5 TIMES
4	CHP	CC 131	OLR ACTED	RESET	02:40:00	02:45:00	
5	CHP	CC 52	FEEDING CONV OLR ACTED	RESET	04:00:00	04:05:00	
6	CHP	CC 29 ZSS	CAGE STUCK WITH MATERIAL	REMOVED	03:45:00	04:00:00	