



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/09/2026

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment        | Problem        | Action     | From     | To       | Remarks |
|-------|------|------------------|----------------|------------|----------|----------|---------|
| 1     | OHP  | RSCO-6A (C)DRIVE | OLR ACTED      | RESET DONE | 06:10:00 | 06:20:00 |         |
| 2     | OHP  | CO-34            | TRIPPED ON OLR | RESET DONE | 08:55:00 | 09:10:00 |         |
| 3     | CHP  | CC-131           | OLR ACTED      | RESET DONE | 13:25:00 | 13:30:00 |         |
| 4     | CHP  | CC-40            | TRIPPED ON OLR | RESET DONE | 11:50:00 | 12:00:00 |         |