



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/06/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 15	VA CCUME CONTACTOR INCOMING B PHASE GOT HIGH TEMPERATURE	MODULE REPLACED WITH SPARE ONE TESTED OK	22:40:00	23:30:00	
2	OHP	CO 25	TRIPPED ON OLR	RESET DONE	23:40:00	23:50:00	
3	OHP	BRC ONCO 32	BC NOT RUNNING/YARD ZSS INTERLOCK PROBLEM	PROBE REPLACED	23:30:00	23:55:00	
4	OHP	CO 29	ZSS ACTING/HIG NOT GETTING TO CJB	PENDING	05:40:00	06:00:00	
5	CHP	SCR 7 ON CC40	BC STOPPING ON ZSS/CASE STUCKUP WITH MATERIAL	CAGE MADE FREE THEN OK	01:10:00	01:30:00	
6	CHP	CC 40	TRIPPED ON OLR	RESET DONE	01:30:00	01:40:00	
7	CHP	CC 131	TRIPPED ON OLR/2TIMES	RESET DONE	02:10:00	02:15:00	
8	WT	OP 4	FORWARD /REVERSE NOT TAKING PLACE/DRIVE 4 OLR ACTED	RESET DONE	03:00:00	03:10:00	