



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/07/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	TRIPPED ON OLR	RESET DONE	07:35:00 10:35:00	07:45:00 10:40:00	
2	OHP	TT 2 ON CO 15	LT NOT TAKING PLACE/MPCB OUTGOING B PHASE GOT LOOSE	B PHASE WIRE TIGHTEND THEN OK	07:30:00	08:00:00	
3	CHP	SCR 3 ON CC37	DRIVE TRIPPED ON OLR	RESET DONE	07:25:00	07:30:00	
4	WT	OT 3	F/ R NOT TAKING PLACE/ DRIVE 2 TRIPPED ON EN CODER FAULT -43	RESET DONE	11:10:00	11:20:00	