



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/06/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	17:00:00	17:10:00	2 times
2	CHP	CC 112 SCR8	slew not working,b/w selected bit not coming,b/w main pump panel power and control is in off condition	made on	18:40:00	19:00:00	
3	CHP	CC 44	olr acted	reset	20:45:00	20:50:00	
4	CHP	CC 47	stopped due to ZSS which acted due to overload	informed operation	21:25:00	21:35:00	
5	CHP	CC 125	olr acted	reset	21:45:00	21:50:00	