



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/08/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 29	TRIPPED ON OLR/3TIMES	RESET DONE	16:15:00 16:55:00	16:20:00 17:05:00	
2	OHP	CO 25	TRIPPED ON OLR	RESET DONE	18:10:00	18:20:00	
3	OHP	CO 26	TRIPPED ON OLR	RESET DONE	20:35:00	20:45:00	
4	OHP	WOBR ON CO 6A	SLEW NOT STOPPING/STOP PB NOT MAKING PROPERLY	STOP PB MADE PROPER CONTACTING THEN OK	20:20:00	20:40:00	
5	CHP	cc 112 scr 8	b/c stopped in zss,probe connection problem	probe connected	14:40:00	14:55:00	
6	CHP	cc 39	conveyor red , CJD acted,module problem	module replaced	16:25:00	16:45:00	
7	CHP	CC132	PC ACTED	RESET DONE	15:50:00	16:05:00	
8	CHP	TT ON CC131	BUNKER POSITION SIGNAL NOT GETTING/CABLE DAMAGED AND FUSE BLOWN	CABLE RE JOINTED THEN OK	16:05:00	16:30:00	
9	CHP	CC 51	MPD TRIPPED ON OLR	RESET DONE	16:35:00	16:40:00	FEEDING C ONV.STOP ED
10	CHP	CC 54	TRIPPED ON OLR	RESET DONE/4TIMES	16:35:00	20:35:00	
11	CHP	CC52	MPD TRIPPED ON OLR	RESET DONE	21:45:00	21:50:00	
12	CHP	CC 14	TRIPPED ON OLR/2TIMES	RESET DONE	19:00:00	19:30:00	