



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/06/2026

Area: WT

Equipment	Job
OP 6	Panel and Motor side ppm done
MIS	Lighting inspection done both coal and ore side
OT 5	Limits inspection done
OP 7	section insulator set replaced @col no 96
AF 5	Lugging done to power cables of drive
MIS	AMTECH failure drives shifted for repair