



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/06/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 5A	LT M1 TRIP	RESET	15:50:00	16:00:00	TRACK JAMMING
2	OHP	CO 25	OLR ACTED	RESET	20:30:00	20:35:00	
3	OHP	CO 35 ZSS	PROBE WIRE GOT CUT	REJOINTED	16:40:00	16:50:00	
4	OHP	BRC ON CO 8A B/W	B/W ZSS MODULE SUPPLY TRIP	MADE IT ON	21:00:00	21:20:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	19:30:00	19:35:00	
6	CHP	SCR 5 ON CC 38	B/C MCCB TRIP	MADE IT ON	16:30:00	16:40:00	
7	CHP	SCR 7 ON CC 40 B/C	ZSS PROBE DAMAGED	REPLACED	20:45:00	21:00:00	
8	CHP	CC 201	OLR ACTED	RESET	15:40:00	15:50:00	
9	CHP	CC 12	CABLE GOT CUT	REJOINTED	18:30:00	18:40:00	