



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/05/2026

Area: OHP

Equipment	Job
co-36,48,49, h/e hoists ; and bombay crane hoist.	ppm is done.
co-36,37,47,48,49	motor and panel side ppm is done.
lc-6 earth pits	testing and inspection of earth pits is done.
co-17,18	field safety devices ppm is done.
co-5,17	motor and panel side ppm is done.
om-12,16, LC-8	housekeeping is done.
hvmcc-1 spare motors	all motors checked and found ok.
tis on co-29	checked along with mechanical and kept in circuit.
cbms of co-6a	provision for magnet lowering is checked and planned.
wobr-4 on co-6a luff limits	checking is done and found working and in circuit.
repair bay ht transformer	tank support welding job is under progress
tbs-1 on co-22 ; tbs-2 on co-20	mcc panels blowing is done.
jh o-14,15,	cctv supply boards fixing purpose support welding is done. supply provided at jh o-14 area.