



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	cc 33 scr 2	b/c not running,zss acted due to coal stucked	cage made free	14:45:00	14:55:00	
2	CHP	CC 36 S1	Lt not working ,M1 mpcb tripped	made it on	16:30:00	16:40:00	
3	CHP	CC 107	motor tripped in olr	reset	21:04:00	21:10:00	2 times
4	CHP	CC 115	BRS acted,sensor covered with dust	sensor cleaning done	17:40:00	17:50:00	
5	WT	CP 2	no movement,no power,acb tripped in LC	acb made on	17:00:00	17:10:00	