



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/05/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC 51	OLR ACTED IN MPD	RESET DONE	06:35:00	06:40:00	
2	CHP	SCR 7 ON CC39	BC NOT RUNNING/30DEGREE LIMIT ACTED	RELEASED THEN OK	06:20:00	06:30:00	
3	CHP	CC 203	MPD TRIPPED ON OLR	RESERT DONE	11:15:00	11:25:00	
4	CHP	SCR 1 ON CC 31	LT NOT TAKING PLACE/PCRD CABLE TENSION ACTED	CABLE TENSION RELEASED	12:40:00	12:55:00	
5	CHP	CC 33	TRIPPED ON OLR	RESET DONE	12:45:00	12:55:00	
6	WT	OP 1	F/REVERSE NOT TAKING PLACE/POWER CONTACTOR NOT MAKING ON DUE TO SPP NOT GETTING R PHASE	SPP RESET DONE AFTER R PHASE TIGHTEN.	12:50:00	13:15:00	R PHASE LOOSE AT TERMINATI ON