



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/09/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR3	oc acted in mpr	reset	08:20:00	08:30:00	
2	OHP	brc 30	bc not running,olr atced	reset	06:10:00	06:25:00	3 times
3	OHP	co 25	olr acted	reset	06:35:00	06:45:00	
4	OHP	tbs on co 21	LT not working,OT acted	reset	10:40:00	11:00:00	
5	CHP	CC 37 STK1	luff problem	all checked found ok	08:00:00	08:10:00	
6	CHP	cc 37 s1	LT not working,olr acted	reset	09:25:00	09:33:00	