



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/09/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 8A	BC NOT RUNNING/LOCAL MODE AT C/D	KEPT IN REMOTE	08:40:00	09:00:00	
2	OHP	CO 11A	BRS ACTED/BELT JOINT OPEN	INFORM TO OPE.	07:50:00	08:00:00	
3	OHP	CO 29	TRIPPED ON OLR	RESET DONE	08:30:00 09:50:00 13:20:00	08:40:00 10:00:00 13:30:00	
4	OHP	CO 29	BRS ACTED/ MODULE CABLE GOT EARTH FAULT	BY PASSED AT CJB AND GIVEN CLEARENCE	10:30:00	10:40:00	INFORM TO G SHIFT ,TO BE KEPT IN CKT
5	OHP	TBS ON CO 22	LT NOT TAKING PLACE/M3 MPCB TRIPPED	MADE ON	11:25:00	11:45:00	
6	OHP	WOBR ON 25	LUFFING NOT TAKING PLACE/LIMIT GOT STUCKUP	LIMIT RELEASED	10:50:00	11:00:00	
7	CHP	CC 54	TRIPPED ON OLR/3TIMES	RESET DONE	08:50:00	09:00:00	
8	CHP	CC 131	TRIPPED ON OLR	RESET DONE	10:00:00	10:05:00	
9	WT	OP 10	F/R NOT TAKING PLACE/COMMUNICATION PROBLEM	POWER RECYCLE DONE AT PUSHER AND CABIN	10:50:00	11:10:00	