



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/06/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 32 LT	LT SKEW ACTED	INFORMED TO MECH	23:00:00	23:15:00	
2	OHP	BRC ON CO 34	INTERLOCK CAGE ZSS SUPPLY MCB TRIP	MADE IT N	23:15:00	23:30:00	
3	OHP	WBR ON CO 29	LUFF OLR ACTED	RESET	23:20:00	23:30:00	
4	OHP	TBS ON CO 20 LBC	ZSS CHECK NUT LOOSE	TIGHTENED	23:45:00	00:00:00	
5	OHP	CO 12	OLR ACTED	RESET	00:00:00	00:10:00	
6	OHP	VS2A	OLR ACTED	RESET	05:50:00	06:00:00	
7	CHP	SCR 7 ON CC 40	LUFF UP LIMIT ACTED	RELEASED	22:35:00	22:50:00	
8	CHP	SCR 2 ON CC 33 LT	DRUM SENSOR ACTED	RELEASED	23:30:00	23:45:00	
9	CHP	CC 44	OLR ACTED	RESET	01:00:00	01:10:00	
10	CHP	SCR 7 ON CC 40 B/C	30 DEGREE LIMIT ACTEDQ	INFORMED TO OPRN	05:00:00	05:10:00	
11	WT	OT4	D1 TRIP	RESET	00:30:00	00:35:00	
12	WT	CP2	BREAKER	TRIP	23:20:00	23:30:00	