



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	olr acted	reset	22:35:00	22:45:00	
2	OHP	BRC on CO 33m	b/c not running,cjd acted due to jamming	informed operation	00:00:00	00:15:00	
3	OHP	co 32	olr acted	reset	01:30:00	01:40:00	
4	OHP	co 26	olr acted	reset	04:00:00	04:10:00	
5	CHP	cc 107	mpd olr acted	reset	01:45:00	01:50:00	
6	CHP	CC 33 SCR2	B/C not working,zss cage got stucked with coal	cage made free	03:25:00	03:40:00	
7	CHP	CC 102	motor bearing temperature high	bypass bit l88.1 in io rack	00:45:00	01:00:00	in program A log_1 missing as compare to CC 103 before motor bearing temp line
8	CHP	CC 51	mpd atced	reset	05:20:00	05:25:00	
9	CHP	CC 131	motor tripped in olr	reset	05:20:00	05:25:00	