RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 28	LT PCRD O/T acted	Released	14:40:00	15:00:00	
2	OHP	BPC 3 ZSS	Cage stuck up	Replaced	16:00:00	17:00:00	
3	OHP	TBS on co 21 Left Luff	OLR Burnt	Replaced	17:00:00	18:00:00	
4	OHP	WBR on CO 26 LT	M4 trip	Reset	18:40:00	19:00:00	
5	OHP	CO 9a	BRS	Bypassed	18:40:00	19:00:00	To Be kept in Circuit
6	OHP	WBR on co 6a	B/C ZSS probe damaged	Replaced	20:20:00	21:00:00	
7	OHP	WBR on co 25 Slew	Jamming	Informed to oprn	20:20:00	21:00:00	
8	OHP	WBR on co 26	OLR acted	Reset	21:00:00	21:15:00	
9	CHP	CC-47	Driver end chute sensor bypassed	.	16:10:00	16:20:00	Operation request
10	CHP	CC-104	Drive end chute sensor and BRS bypassed	.	16:00:00	16:20:00	operation request
11	CHP	CC-126	Belt sway acted due to common high fuse blown	Fuse changed and made OK	16:10:00	16:25:00	
12	CHP	SCR-7 ON CC-40	BC not working. MPD tripped	Reset done	16:45:00	16:55:00	

वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	SCR-2 ON CC-33	LT not working. Drum sensor acted	Reset done and made OK	17:30:00	17:40:00	
14	CHP	CC-125	BRS bypassed	.	18:50:00	19:00:00	Operation request