RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 29/10/2026

Area: OHP

Equipment	Job
CO-6A	BRS SMPS PROBLEM ... smps changed and brs kept in ckt
CO-5A TBS	CONTROL TRANSFORMER MCB CHANGED AND TESTED
CO-22 TBS	FAILED CONTROL TRANSFORMER REMOVED AND NEW FIXED .... SELECTOR SWITCH NEEDS TO BE CHANGED
CO-50 HOIST	CT MOTOR BURNT ... CT MOTOR CHANGED
CO-57 GALLERY	LIGHTING RECTIFIED
CO-51 CHUT VIBRATOR	FUSE CHANGED IN OM-9 AMD TESTED
MIC	CO-46 HE WELDING MACHINE SUPPLY MCCB CHANGED IN LC-6
CO-44	VFD SUPPLY ACB RACKED IN