



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/10/2026

Shift: B

Incharge(s): D K Verma, Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 32 B/C	Stone stuck up in ZSS Cage	Removed	17:00:00	17:20:00	
2	OHP	WBR 3 on CO 25	Slew Limit stuck	Made it Free then ok	17:10:00	17:30:00	
3	OHP	CO 26	OLR acted	Reset	17:40:00	20:50:00	2 times
4	OHP	VS4	MPCB trip	Reset	20:05:00	20:10:00	
5	CHP	CC 131	OLR acted	Reset	17:40:00	21:40:00	2 times
6	CHP	SCR 2 on CC 33 LT	Drive trip	Reset	15:45:00	15:55:00	
7	CHP	SCR 10 on CC 105	Signal Problem	LT done	18:40:00	18:55:00	
8	CHP	SCR 8 on CC 112 B/C	Coal stuck in ZSS cage	Removed	20:40:00	20:55:00	