



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/08/2026

Incharge(s): Nagendra Midde, K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED (2TIMES)	RESET DONE	15:15:00 18:45:00	15:25:00 18:55:00	
2	OHP	CO-25	OLR ACTED	RESET DONE	19:10:00	19:20:00	
3	OHP	RSCO-6A (C) DRIVE	OLR ACTED	RESET DONE	15:00:00	15:20:00	