



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/07/2026

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-26	B/C OLR ACTED (DUO TO MATERIAL OVER LOAD)	RESET DONE	09:45:00	10:00:00	
2	CHP	CC-52	MPD TRIP (FEEDING CONVEYOR STOP)	RESET DONE	09:15:00	09:20:00	
3	CHP	CC-54	OLR ACTED (2TIMES)	RESET DONE	07:45:00	08:00:00	
4	WT	AF-1	REPORTED NOT RUNNING CHECKED AND FOUND E/STOP ACTED	RELEASED THAN OK	12:15:00	12:35:00	