



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/09/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav,G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	TRIPPED ON OLR	RESET DONE	00:25:00	00:35:00	
2	OHP	WOBR ON CO 25	LT NOT TAKING PLACE/M1 M2 DUE TO TRACK JAMMING	RESET DONE AFTER CLEARANCE	02:30:00	02:50:00	
3	OHP	BRC ON CC32	LT SKEW ACTED DUE TO TRACK JAMMING	INFORMED TO OPERATION	04:45:00	04:59:00	CJD BYPASSED ,NOW KEPT IN CKT
4	OHP	co 43 a	OLR ACTED	reset	02:15:00	02:30:00	
5	CHP	SCR 3 ON CC36	LT NOT TAKING PLACE/DRIVE TRIPPED ON OVN FAULT	RESET DONE/2TIMES	22:25:00	22:35:00	
6	WT	OP 4	F/R NOT TAKING PLACE M3 TRIPPED ON OLR	RESET DONE	03:15:00	03:25:00	
7	IOSA	OC 14A	HEALTHY STOP	DIDNT FOUND ANY PROBLEM	02:10:00	02:20:00	