



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/06/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.Reset done	02:40:00 22:05:00	02:50:00 22:15:00	
2	CHP	CC-39 SCR-7	LT not working	Drive tripped.Reset done	23:35:00	23:45:00	
3	CHP	CC-32 SCR-4	LT not working	PCRD tension acted.Released	04:55:00	05:05:00	
4	CHP	CC-51	MPD tripped	Feeding conveyor stopped.Reset done	01:00:00	01:05:00	