वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 20/10/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	TRIPPED ON OLR	RESET DONE	06:05:00 07:40:00	06:15:00 07:50:00	
2	OHP	BRC ON CO 31	BC NOT RUNNING/EMERGENCY STOP PB OPERATED	PB RELEASED	08:40:00	08:45:00	
3	OHP	CO 34	TRIPPED ON OLR	RESET DONE	09:00:00	09:05:00	
4	CHP	CC 203	TRIPPED ON OLR	RESET DONE	06:30:00	06:40:00	
5	CHP	CC 51	MPD TRIPPED ON OLR	RESET DONE	12:10:00 12:25:00	12:15:00 12:30:00	
6	CHP	SCR 3 ON CC 37	BC NOT RUNNING/MPD TRIPPED ON SP	RESET DONE	07:30:00	07:40:00	
7	CHP	SCR 3 ON CC37	BC NOT RUNNING/CS ACTED/CHUTE JAMMING	IN FORM TO OPERATION	07:55:00	08:10:00	
8	CHP	CC 32	TRIPPED ON OLR	RESET DONE	13:35:00	13:45:00	
9	CHP	SCR 5 ON CC 32	LT NOT TAKING PLACE/PCRD TENSION ACTED	TENSION RELEASED	07:45:00	07:55:00	
10	CHP	SCR 6 ON CC38	BC NOT RUNNING/MATERIAL JAMMING	BELT SLIP /INFORM TO OPERATION	08:40:00	09:00:00	
11	CHP	SCR 4 ON CC 111	BC NOT RUNNING	POWER RECYCLE DONE THEN OK	09:25:00	09:40:00	
12	CHP	SCR 9 ON CC 104	SLEW NOT TAKING PLACE/MCCB TRIPPED	MCCB MADE ON	09:50:00	10:10:00	