



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/05/2026

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-10A CD	TRIPPED ON OL	RESET DONE	14:40:00	14:50:00	
2	OHP	TT-3	PCRD CABLE STUCK	UNWINDING AND WINDING DONE	14:15:00	14:40:00	
3	OHP	CO-30 BRC	ALL DRIVES NOT RUNNING ... R PHASE NO POWER	HT MADE OFF ... TRANSFORMER OPENING JOB GOING ON	21:30:00	22:00:00	CHECKING GOING ON
4	CHP	CC-33 SCR-2	SLEW DRIVE TRIP ON OL	RESET DONE	16:25:00	16:40:00	
5	CHP	CC-33 SCR-2	BW DRIVE TRIPPED	RESET DONE	18:30:00	18:45:00	
6	CHP	CC-104 SCR-6	TUL C/S ACTED ...MODULE PROBLEM BYPASSED	MODULE CHANGED AND KEPT IN CKT	18:50:00	19:05:00	
7	CHP	TT-3	C/S MODULE PROBLEM	REPLACED AND TESTED	16:35:00	17:35:00	
8	CHP	CC-54	TRIPPED ON OLR	RESET DONE	17:05:00	17:10:00	