RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/10/2026

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR on CO 6a	Break 2 OLR fault	Disconnected	06:35:00	06:55:00	
2	OHP	WBR on CO 6a	B/W Solenoid valve stuck	Made it free	12:35:00	12:55:00	
3	OHP	BRC on CO 32 LT	Drive 2 (CRMP) trip	Reset	13:35:00	13:45:00	
4	OHP	TBS on CO 24 LT	Break tight	Informed to mech	08:30:00	08:45:00	
5	CHP	SCr 7 on CC 40	B/C OLR acted	Reset	09:25:00	09:35:00	
6	CHP	CC 131	Panel out going to Motor Tb cable Y phase Earth Fault	Checking under progress	13:20:00	14:00:00	
7	WT	CO 3	OLR acted	Reset	06:00:00	06:30:00	2 times