RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRc on CO 32	ACB in off condition	Made it on	15:20:00	15:35:00	
2	OHP	BRC on CO 8a	Lt M1 Trip	Reset	18:40:00	18:55:00	One Bhogi Derailed
3	OHP	CC 25	OLR acted	Reset	19:10:00	19:20:00	
4	OHP	BRC on CO 30 B/C	OLR acted	Reset	19:40:00	19:50:00	
5	OHP	WBR on CO 29 B/W	OLR acted	Reset	20:55:00	21:10:00	
6	CHP	CC 47	Selector switch in local mode	Changed to Remote	20:05:00	20:15:00	
7	CHP	CC 58	OLR acted	Reset	17:10:00	17:25:00	
8	CHP	CC 51	Feeding conv olr acted	Reset	21:10:00	21:15:00	
9	CHP	S3 on CC112	Old HT Joint Failure	After DNW clearance Charged	15:00:00	19:00:00	