RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 25/10/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	23:30:00	23:40:00	2times
2	OHP	co 26	olr acted	reset	01:15:00	01:25:00	3 times
3	OHP	co 34	olr acted,jamming	reset	05:15:00	05:20:00	
4	OHP	brc on co 34	LT not working,OT acted	released	03:00:00	03:10:00	
5	OHP	tbs on co 20	R luff olr acted	reset	02:20:00	02:30:00	
6	OHP	wobr on co 29	LT not working,drive tripped	reset	05:05:00	05:15:00	
7	OHP	CF1	failed to start	i/o rack panel CMD relay tightened	01:15:00	01:30:00	
8	OHP	VF 10 A	ol acted	reset	22:37:00	22:47:00	
9	CHP	CC 31 SCR1	b/c not working in reclaiming mode	CCR side problem	02:10:00	02:25:00	
10	CHP	CC 104 scr9	b/w not working	wrong complaint	02:35:00	02:45:00	