



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/10/2026

Area: OHP

Equipment	Job
All Yard stacking conveyors BSS	checked and restored in circuit. co-14b point main gate side switch is replaced.
wbr-2 on co-29	pcrd motor is fixed in place and termination is done.