



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/10/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	Reset	15:35:00	15:45:00	
2	OHP	VS2	OLR acted	Reset	17:45:00	17:55:00	
3	OHP	VF8a	Control MCB trip	Made it on	19:20:00	19:30:00	
4	OHP	BRC on CO 8a	B/W2 Charge Pressure Acted	Informed to Mech	21:15:00	21:30:00	
5	CHP	CC 22	OLR acted	Reset	14:15:00	14:40:00	
6	CHP	CC 201 ZSS	Cage stuck	Made it Free	16:15:00	16:30:00	
7	CHP	SCR 8 on CC 106	B/W Charge pressure acting	Informed to mech	16:55:00	17:20:00	