



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	18:25:00	18:35:00	
2	OHP	CR 2A	zss acted,probe disturbed	probe adjustment done	18:30:00	19:00:00	
3	OHP	TT 1	position on co 7A not coming	bypassed in I/O rack	19:20:00	19:30:00	
4	CHP	cc 54	olr acted	reset	21:00:00	21:10:00	