



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/07/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	06:35:00	06:45:00	
2	OHP	WOBR on CO 25	LT not working,OT acted	OT released	06:35:00	06:45:00	
3	OHP	CR 2A	tripped in unbalanced load,checked and found R phase lug got cut in TB	megger done ,lugging done	08:00:00	11:55:00	
4	CHP	CC 131	tripped	reset	08:40:00	08:45:00	3 times