



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/09/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	SCR 3 on CC 37	B/C Olr acted	Reset	00:30:00	04:45:00	2 times
2	CHP	SCR 6 on CC 38 Slew	Limits Common High Mcb Tripped	Made it on	01:20:00	01:40:00	
3	CHP	SCR 2 on CC 33 B/C	OLR acted	Reset	03:15:00	03:30:00	
4	CHP	SCR 9 on CC 104	ACB trip	Made it on	04:00:00	04:20:00	
5	CHP	CC 112 DE	C/S bypassed	Due to Rain	02:00:00	02:10:00	