



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/10/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 14 B	TRIPPED ON OLR	RESET DONE	11:30:00	11:40:00	
2	OHP	CO 32	PC ACTED DUE TO CABLE CUT BY BOBCAT	PC BYPASSED AT CJB	11:35:00	11:50:00	
3	OHP	CO 15A	ZSS ACTED/CAGE PROBLEM	TEMPORARY BYPASSED AND AGAIN KEPT IN CKT	07:30:00	07:40:00	CAGE REPLACED
4	OHP	WOBR ON CO 29	LUFFING NOT WORKING/BOOM AT LOWER LEVEL AND BW JAMMING WITH MATERIAL	NO ELECTRICAL PROBLEM	06:50:00	07:00:00	
5	OHP	WOBR ON CO 25	NO DRIVES RUNNING/ EMERGENCY DOWN LIMIT ACTED	EMERGENCY LIMITS BYPASSED AND AGAIN KEPT IN CKT AFTER LIMIT RELEASED	06:45:00	07:00:00	
6	OHP	BRC ON CO 30	BC NOT RUNNING/TRIPPED ON OLR	RESET DONE	12:15:00	12:25:00	
7	OHP	BRC ON CO 30	CT NOT TAKING PLACE/DRIVE TRIPPED ON OLR	RESET DONE	12:40:00	12:45:00	
8	OHP	CO 26	TRIPPED ON OLR	RESET DONE	09:00:00	09:10:00	
9	OHP	WOBR ON CO 25	RIGHT SLEW NOT TAKING PLACE/LIMIT STUCK	RELEASED THEN OK	09:10:00	09:20:00	
10	CHP	CC 51	MPD TRIPPED ON OLR/FEEDING CONV. STOP	RESET DONE	13:00:00	13:05:00	
11	CHP	CC 113	TRIPPED ON OLR	RESET DONE	12:45:00	12:55:00	